



Product Service

# CERTIFICATE

No. B 105620 0030 Rev. 00

**Holder of Certificate:** Zhejiang Tengen Electric Co., Ltd.  
Sulv Industrial Area, Liushi Town  
325604 Yueqing City  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** Moulded case circuit breaker

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 874102500511-00

**Valid until:** 2030-03-24

**Date,** 2025-03-25

( Hongbo Zhu )

# CERTIFICATE

No. B 105620 0030 Rev. 00

**Model(s):** **TeM7-400, TeM7-630, TeM7-400HU, TeM7-630HU**

## Parameters:

Rated impulse withstand voltage ( $U_{imp}$ ):	12kV
Rated insulation voltage ( $U_i$ ):	1250V
Rated operational voltage ( $U_e$ ):	TeM7-400, TeM7-630: AC380V/AC400V/AC415V, AC500V/AC550V, AC660V/AC690V; TeM7-400HU, TeM7-630HU: AC690V /AC800V
Rated frequency:	50/60Hz
Rated current ( $I_n$ ):	TeM7-400, TeM7-400HU: 250A, 315A, 320A, 350A, 400A; TeM7-630, TeM7-630HU: 400A, 500A, 630A
Rated service short-circuit breaking capacity ( $I_{cs}$ ):	See below table 1
Rated ultimate short-circuit breaking capacity ( $I_{cu}$ ):	See below table 1
Selectivity category:	A
Type of overcurrent release:	Thermal-magnetic type, electro-magnetic type
Number of poles:	3P, 3P+N (3 protected phase poles + non-switched N pole), 3P+N (4 protected poles + non-switched N pole), 4P (3 protected pole, switched N pole), 4P
Suitable for isolation:	Yes, except 3P+N products
Suitable for IT system:	Yes, except AC690V/800V products
Information of accessories:	Auxiliary / alarm contact matched: 1NO1NC, 2NO2NC, 3NO3NC, 4NO4NC $U_i$ : 400V, $U_{imp}$ : 4kV, $I_{th}$ : 3A AC-15: AC400V/1,5A; DC-13: DC220V/0,15A Electrical operator: $U_s$ : DC24V, DC110V, DC220V, AC110V, AC230V, AC400V; 50/60Hz Shunt release, undervoltage release: $U_s$ : AC230V, AC400V; 50/60Hz

# CERTIFICATE

No. B 105620 0030 Rev. 00

Table 1:

Model	Rated voltage	Breaking capacity type	I <sub>cs</sub> (kA)	I <sub>cu</sub> (kA)
TeM7-400 TeM7-630	AC380/400/415V	L	50	50
		M	85	85
		H	100	100
		S	150	150
		R	200	200
	AC500/550V	L	50	50
		M	50	50
		H	70	70
		S	70	70
		R	85	85
	AC660/690V	L	20	20
		M	20	20
		H	40	40
		S	50	50
		R	50	50
TeM7-400HU TeM7-630HU	AC690V/800V	M	40	40
		H	50	50

Tested according to: EN 60947-2:2017/A1:2020